

**A Type : Cord + Switch**

**P/S UNIT(F1)-xxA**

5PSF2xx01W01/02


P/S UNIT(F1)-xxA / [ 8/10/14 WAY ]



1	PLUG[15A 250V (KS C 8305)] : 동양전자산업 / CABLE[2.5mm * 3C (KS C IEC 60227-5 IEC53)] : 동일전선
2	과부하 차단 SWITCH [16A 250v ] : 화필

5PSF2xx1001

P/S UNIT(F1)-xxA(Pair) / [ 10/14/17 WAY ]



1	PLUG[15A 250V (KS C 8305)] : 동양전자산업 / CABLE[1.5mm * 3C (KS C IEC 60227-5 IEC53)] : 동일전선
2	과부하 차단 SWITCH [16A 250v ] : 화필

**B Type : Cord + Switch + Amperemeter**

**P/S UNIT(F1)-xxB**

5PSF2xx02W01/02

P/S UNIT(F1)-xxB / [ 10/14 WAY ]



1	PLUG[15A 250V (KS C 8305)] : 동양전자산업 / CABLE[1.5mm * 3C (KS C IEC 60227-5 IEC53)] : 동일전선
2	과부하 차단 SWITCH [16A 250v ] : 화필
3	AMPERE METER [15A 250V ( 전류표시범위 : 0.5~25.5A)] : 케이원

C Type : 단자대 + Switch  
P/S UNIT(F1)-xxC

5PSF2xx03W01  
P/S UNIT(F1)-xxC / [ 10/14 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	배선용 차단기 [30A 220V ] : 화פל

5PSF2xx06W01  
P/S UNIT(F1)-xxC / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [16A 250V, 차단전류 2.5kA ] : LS산전

5PSF2xx1101  
P/S UNIT(F1)-xxC(Pair) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [16A 250V, 차단전류 2.5kA ] : LS산전

5PSF2xx1801  
P/S UNIT(F1)-xxC(Legrand) / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [16A 250V, 차단전류 2.5kA ] : LS산전
3	CONNECTOR (Legrand L630-C)
4	PLUG ( Legrand :630-P )

5PSF2xx1901  
P/S UNIT(F1)-xxC(Pair/Legrand) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [16A 250V, 차단전류 2.5kA ] : LS산전
3	CONNECTOR (Legrand L630-C)
4	PLUG ( Legrand :630-P )

D Type : 단자대 + Amperemeter

P/S UNIT(F1)-xxD

5PSF2xx04W01

P/S UNIT(F1)-xxD / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	AMPERE METER [15A250V (전류표시범위 :0.5~25,5A)] : 케이원

5PSF2xx05W01


P/S UNIT(F1)-xxD / [ 5/10/14/20 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원

5PSF2xx1201 [P/S UNIT(F1)-xx(Pair)]

P/S UNIT(F1)-xxD(Pair) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원

5PSF2xx2001

P/S UNIT(F1)-xxD(Legrand) / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA] : LS산전
3	CONNECTOR (Legrand L630-C)
4	PLUG ( Legrand :630-P )

5PSF2xx2101

P/S UNIT(F1)-xxD(Pair/Legrand) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 $\phi$ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA] : LS산전
3	CONNECTOR (Legrand L630-C)
4	PLUG ( Legrand :630-P )

E Type : 단자대 + Switch + Amperemeter  
P/S UNIT(F1)-xxE

5PSF2xx07W01  
P/S UNIT(F1)-xxE / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 ϕ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA ] : LS산전
3	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원

5PSF2xx1301 [P/S UNIT(F1)-xxE(Pair)]  
P/S UNIT(F1)-xxE(Pair) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 ϕ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA ] : LS산전
3	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원

5PSF2xx2201  
P/S UNIT(F1)-xxE(Legrand) / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 ϕ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA ] : LS산전
3	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원
4	CONNECTOR (Legrand L630-C)
5	PLUG ( Legrand :630-P )

5PSF2xx2301  
P/S UNIT(F1)-xxE(Pair/Legrand) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 ϕ 5)] : 전오전기
2	과부하 차단 SWITCH [30A 220V, 차단전류 2.5kA ] : LS산전
3	AMPERE METER [30A250V (전류표시범위 :1.2~51,0A)] : 케이원
4	CONNECTOR (Legrand L630-C)
5	PLUG ( Legrand :630-P )

F Type : 단자대  
P/S UNIT(F1)-xxF

5PSF2xx1401  
P/S UNIT(F1)-xxF [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 ϕ5)] : 전오전기
---	-------------------------------

5PSF2xx1501  
P/S UNIT(F1)-xxF(Pair) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 ϕ5)] : 전오전기
---	-------------------------------

5PSF2xx0901  
P/S UNIT(F1)-xxF(Legrand) / [ 10/14/20 WAY ]



1	단자대 [50A 660V (내경 ϕ5)] : 전오전기
2	CONNECTOR (Legrand L630-C)
3	PLUG ( Legrand :630-P )

5PSF2xx2401  
P/S UNIT(F1)-xxF(Pair/Legrand) / [ 10/14/17 WAY ]



1	단자대 [50A 660V (내경 ϕ5)] : 전오전기
2	CONNECTOR (Legrand L630-C)
3	PLUG ( Legrand :630-P )

G Type : 단자대 + LED  
P/S UNIT(F1)-xxG

5PSF2xx1601

P/S UNIT(F1)-xxG / [ 10/14/20WAY ]



1	단자대[50A 660V (내경 ϕ 5)] : 전오전기
2	LED (Green)

5PSF2xx1701

P/S UNIT(F1)-xxG(Pair) / [ 10/14/17 WAY ]



1	단자대[50A 660V (내경 ϕ 5)] : 전오전기
2	LED (Green)

5PSF2xx2501

P/S UNIT(F1)-xxG(Legrand) / [ 10/14/20 WAY ]



1	단자대[50A 660V (내경 ϕ 5)] : 전오전기
2	LED (Green)
2	CONNECTOR (Legrand L630-C)
3	PLUG ( Legrand :630-P )

5PSF2xx2601

P/S UNIT(F1)-xxG(Pair/Legrand) / [ 10/14/17 WAY ]



1	단자대[50A 660V (내경 ϕ 5)] : 전오전기
2	LED (Green)
2	CONNECTOR (Legrand L630-C)
3	PLUG ( Legrand :630-P )